

# EC-CERTIFICATE OF CONFORMITY

**0336 - CPD - 6742 – 1**

In compliance with Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive-CPD), amended by Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

## **Natural smoke and heat exhaust ventilator**

Commercial name(s):

**Certilam and Certilux**

placed on the market by

**Souchier S.A.S.**

and produced in the factory

**Souchier S.A.S**

**11 rue du 47ème Régiment d'Artillerie**

**70400 HERICOURT**

**France**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body 1234-Efectis Nederland B.V, 1812-Efectis France S.A and 1368-IFI Institute for Industrial aerodynamics GmbH have performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control system are inspected by 0336-TÜV Rheinland Nederland B.V. and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

**EN 12101-2**

were applied and that the product fulfils all the prescribed requirements (annex 1).

This certificate was first issued on **29<sup>th</sup> August 2006** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Apeldoorn, 21 November 2012

**TÜV Rheinland Nederland B.V.**  
**Boogschutterstraat 11A**  
**NL – 7324 AE Apeldoorn**  
**The Netherlands**



Managing Director TÜV Rheinland Nederland B.V.

This certificate consists of 1 certificate and 1 annex of 2 pages

# EC-CERTIFICATE OF CONFORMITY

0336 - CPD - 6742 – 1

## Annex 1

### Natural smoke and heat exhaust ventilator

Commercial name(s):  
**Certilam and Certilux**

#### Field of Application

1 m<sup>2</sup> < A<sub>v</sub> < 6 m<sup>2</sup> with, 500 mm < L < 3.000 mm and 786 mm < l < 3.046 mm

#### The classifications for this dimensional range are:

##### Classification:

- Cv = 0,62 on wall installation and roof installation without upstand
- Cv = 0,67 on roof installation with upstand
- Re 1000(+10.000), with exception for mechanical opening Re 300 (+10000), dual purpose allowed
- SL 250 and SL 500
- T(-25), T(-15) for electrical powered opening and electrical powered security position fixation
- WL 1500
- B300
- Reaction to fire: B-s1, d0 (fillings PCA and thermal or acoustical insulating function)  
A 1 (glass filling or single layer metal filling)

TÜV Rheinland Nederland B.V.  
Boogschutterstraat 11A  
NL – 7324 AE Apeldoorn  
The Netherlands



Managing Director TÜV Rheinland Nederland B.V.

This certificate consists of 1 certificate and 1 annex of 2 pages